


بسم الله الرحمن الرحيم

هيئة الاتصالات الخاصة

إعلان طرح عطاء



شراء محركات عدد (٥) لهيئة الاتصالات الخاصة.

تعلن هيئة الاتصالات الخاصة في القيادة العامة للقوات المسلحة الاردنية - الجيش العربي/شعبة التزويد عن طرح عطاء رقم هـ أ خ/ت/١٤ / ٢٠٢٤ شراء محركات عدد (٥) لهيئة الاتصالات الخاصة. على المتعهدين الراغبين بالاشتراك بهذا العطاء مراجعة هيئة الاتصالات الخاصة/ شعبة التزويد لشراء نسخة من دعوة العطاء مقابل دفع مبلغ (٥٠) دينار غير مستردة مصطحبين معهم رخصة المهن والسجل التجاري ساريتي المفعول وصورة عنهما وكتاب تفويض من الشركة لمندوبها.

يتم بيع نسخة دعوة العطاء يومياً من الساعة (٠٩٠٠) التاسعة صباحاً يوم الأحد الموافق ٢٠٢٤/١٠/٦ لغاية يوم الاثنين الموافق ٢٠٢٤/١١/٤ الساعة (١٤٠٠) الثانية ظهراً (باستثناء أيام العطل الرسمية).

تعاد المناقصات بواسطة الظرف المختوم (عرض فني ومالي منفصلين) قبل الساعة (١٤٠٠) الثانية ظهراً من يوم الثلاثاء الموافق (٢٠٢٤/١١/٥) ومرفق بها تأمين مالي مصدق بقيمة (٣%) من القيمة الاجمالية المعروضة (حسب أعلى سعر معروض) وكل مناقصة غير مرفق بها التأمين المالي او قيمة التأمين المالي أقل من المطلوب تهمل ولا ينظر بها وكل مناقصة ترد متأخرة عن موعد الاغلاق أعلاه ترفض ولن يتم استلامها.

عنوان هيئة الاتصالات الخاصة:

تلفون: (٥٠٥٩١١٨)

فاكس: (٥٠٥٠١٠٤)

<https:// Scc.jaf.mil.jo/>

E-mail: supply1@scc.org.jo

الملحق (ب)

Standby AC – three phase – diesel generator set with 100Ah motorized ATS panel

• **QUANTITY = 5 GENERATOR SET.**

#	Characteristics	Description	Note
1	Nominal voltage L-L	380-400v AC	
2	Nominal voltage L-N	220-230v AC	
3	Nominal capacity	20 KVA	
4	Nominal frequency	50 Hz	
5	Fuel type	Euro 5	
6	Generator type	Canopied	
7	Cooling	Water cooling	
8	Performance grade	G2 OR G3	With certificate
9	Control panel	Deepsea electronics	
10	Alternator	Meccalti , Stamford	
11	Starting Battery	12v	With battery charger
12	Governor	Electrical	
13	Fuel tank capacity	300-400 litter	Base tank
14	Oil replacement valve	Outer canopy valve	
15	Water heater	Heating jacket	
16	Automatic transfer switch ATS	3-phase 100A motorized ATS panel	With each generator set
17	Usage	Standby	
18	Exhaust	Sound proof silencer	
19	MCCB	4 pole	
20	Protection	- Over / Under voltage. - Over current. - Over / Under frequency. - Emergency stop button. - Phase failure.	
21	Standards	IEC 60034 , ISO 5828 , ISO 3046	
22	Delivery	20 week	Delivery to SCC warehouses